



**BUTLER SCHOOL DISTRICT
LEAD IN DRINKING WATER
FIRST DRAW SAMPLING REPORT**

PERFORMED FOR:

**BUTLER SCHOOL DISTRICT
38 BARTHOLDI AVENUE
BUTLER, NJ 07405**

PERFORMED BY:

**WESTCHESTER ENVIRONMENTAL LLC
1248 WRIGHTS LANE
WEST CHESTER, PA 19380**

JANUARY 2022



February 4, 2022

Mr. Joe Scaparro
Butler School District
38 Bartholdi Avenue
Butler, NJ 07405

Re: LEAD IN DRINKING WATER REPORT- FIRST ROUND SAMPLING

Dear Mr. Scaparro,

Please find enclosed the report for the Lead in Drinking Water-First Draw Sampling conducted for Butler School District.

If you have any questions, please contact me at 610-431-7545 or email me at nabraham@westchesterenvironmental.com.

Sincerely,

Westchester Environmental, LLC

A handwritten signature in black ink, appearing to read 'Noel Abraham', is written over a horizontal line.

Noel Abraham
Environmental Specialist



TABLE OF CONTENTS

BUTLER SCHOOL DISTRICT

1.0	INTRODUCTION.....	1
2.0	SUMMARY OF FINDINGS.....	2
3.0	SAMPLING AND ANALYSES.....	8
4.0	DISCUSSION & RECOMMENDATIONS.....	9
5.0	DISCLAIMER.....	10

Appendix I – Water Sampling Chain-of-Custody & Laboratory Reports



1.0 INTRODUCTION

Westchester Environmental, LLC was contracted by Mr. Joe Scaparro to conduct Drinking Water Sampling at the following Butler School District buildings:

1. Butler High School
2. Aaron Decker School
3. Richard Butler School

The purpose of the sampling was to collect first draw drinking water samples at predetermined locations in the three facilities and have them analyzed for lead levels.

The water sampling was performed on December 11, 2021 by Noel Abraham of Westchester Environmental, LLC.

All samples were analyzed by Suburban Testing Labs located at 1037 MacArthur Rd, Reading, PA 19605, a New Jersey certified Lead in Drinking Water testing facility.

-END OF SECTION-



2.0 SUMMARY OF FINDINGS

First Draw samples were collected and submitted for lead analysis. Tables 1-3 below shows the concentration of lead (parts per billion or microgram per liter) at each location sampled.

Table 1: Butler High School

	Location Code	Result (ppb)	Action Level (ppb)	Lead Hazard (Yes/No)
1	BHS-LL-SPOE-Boys Rm near 118	<1.00	15.5	No
2	BHS-LL-DW-Hall o/s 101	2.34	15.5	No
3	BHS-LL-DW-Hall o/s Guidance	<1.00	15.5	No
4	BHS-LL-WC-Hall o/s 129	4.49	15.5	No
5	BHS-ML-WC-Hall o/s attendance	<1.00	15.5	No
6	BHS-ML-BF-Hall o/s attendance	<1.00	15.5	No
7	BHS-ML-WC-Hall o/s 210	5.63	15.5	No
8	BHS-TL-FS-Faculty Room	2.16	15.5	No
9	Art Bldg-LL-SPOE- Boiler Room	<1.00	15.5	No
10	Art Bldg-ML-NS-Nurse	<1.00	15.5	No
11	Art Bldg-ML-NS-Nurse Patient Rm	23.4	15.5	Yes
12	Art Bldg-ML-S-Sky lands Rm	<1.00	15.5	No
13	Art Bldg-ML-IM-Trainers Rm	<1.00	15.5	No
14	Art Bldg-ML-S-Trainers Rm	<1.00	15.5	No
15	Art Bldg-ML-WC-Hall o/s Weight Rm	<1.00	15.5	No
16	Art Bldg-ML-BF-Hall o/s Weigth Rm	<1.00	15.5	No
17	Art Bldg-ML-WC-Hall o/s Girls Rm	5.71	15.5	No
18	Art Bldg-ML-WC-Cafeteria Left	<1.00	15.5	No
19	Art Bldg-ML-BF-Cafeteria Left	<1.00	15.5	No
20	Art Bldg-ML-WC-Cafeteria Right	<1.00	15.5	No
21	Art Bldg-ML-WC-Boys Locker Rm	<1.00	15.5	No
22	Art Bldg-ML-BF-BOYS LOCKER RM	<1.00	15.5	No
23	Art Bldg-ML-WC-Girls Locker Rm	<1.00	15.5	No
24	Art Bldg-ML-BF-Girls Locker Rm	<1.00	15.5	No
25	Art Bldg-ML-FP-Kitchen 2	1.61	15.5	No
26	Art Bldg-ML-FP-Kitchen 3	2.63	15.5	No
27	Art Bldg-LL-WC-Bsmt Locker RM	1.34	15.5	No
28	Art Bldg-TL-WC-Hall o/s Rm 335 Left	9.25	15.5	No
29	Art Bldg-TL-WC-Hall o/s Rm 335 Right	2.42	15.5	No
30	Art Bldg-TL-WC-Hall O/s Rm 336	<1.00	15.5	No
31	Art Bldg-TL-BF-Hall O/s Rm 336	<1.00	15.5	No



Location Code	Result (ppb)	Action Level (ppb)	Lead Hazard (Yes/No)
32 Art Bldg-TL-FP-Foods Lab 1	1.9	15.5	No
33 Art Bldg-TL-FP-Foods Lab 2	2.54	15.5	No
34 Art Bldg-TL-FP-Foods Lab 3	2.68	15.5	No
35 Art Bldg-TL-FP-Foods Lab 4	2.43	15.5	No
36 Art Bldg-TL-FP-Foods Lab 5	4.06	15.5	No
37 Art Bldg-TL-FP-Foods Lab 6	1.97	15.5	No
38 Art Bldg-TL-S-AD Office 334 L	111	15.5	Yes
39 Art Bldg-TL-S-AD office 334 R	122	15.5	Yes
40 Art Bldg-TL-WC-Hall o/s BOE Offices	<1.00	15.5	No
41 Art Bldg-TL-BF-Hall o/s BOE Office	<1.00	15.5	No
42 Art Bldg-TL-S-BOE Office Rm 13	<1.00	15.5	No

Table 2: Aaron Decker School

Location Code	Result (ppb)	Action Level (ppb)	Lead Hazard (Yes/No)
43 BAD-1FL-SPOE-Kitchen	<1.00	15.5	No
44 BAD-1FL-FP1-Kitchen	3.14	15.5	No
45 BAD-1FL-KO-Kitchen	4.54	15.5	No
46 BAD-1FL-WC-Hall o/s Kitchen	<1.00	15.5	No
47 BAD-1FL-BF-Hall o/s Kitchen	<1.00	15.5	No
48 BAD-1FL-NS- Nurse	<1.00	15.5	No
49 BAD-1FL-FS-Faculty Rm	1.81	15.5	No
50 BAD-1FL-WC-Hall o/s Rm 28	<1.00	15.5	No
51 BAD-2FL-BF-HALL o/s Rm 28	<1.00	15.5	No
52 BAD-2FL-WC-Hall o/s Rm 35	<1.00	15.5	No
53 BAD--BF-Hall o/s Rm 35	<1.00	15.5	No
54 BAD--FS-Faculty Rm 36	3.22	15.5	No



Table 3: Richard Butler School

	Location Code	Result (ppb)	Action Level (ppb)	Lead Hazard (Yes/No)
55	BRB-1FL-POE-Boiler Room	<1.00	15.5	No
56	BRB-1FL-FP-Special Services	52.4	15.5	Yes
57	BRB-1FL-FP-Kitchen	5.77	15.5	No
58	BRB-1FL-FS-Faculty 156	3.22	15.5	No
59	BRB-1FL-WC-Hall o/s Guidance-L	<1.00	15.5	No
60	BRB-1FL-BF-Hall o/s Guidance-R	<1.00	15.5	No
61	BRB-1FL-WC-Hall o/s 119 Left	<1.00	15.5	No
62	BRB-1FL-WC-Hall o/s Nurse-L	<1.00	15.5	No
63	BRB-1FL-BF-Hall o/s Nurse-R	<1.00	15.5	No
64	BRB-1FL-NS-Nurse	2.97	15.5	No
65	BRB-1FL-WC-Hall o/s Gym-L	<1.00	15.5	No
66	BRB-1FL-BF-Hall o/s Gym-L	<1.00	15.5	No
67	Field Blank	<1.00	15.5	No

-END OF SECTION-



3.0 SAMPLING AND ANALYSES

The following guidance documents were followed for all sampling:

1. N.J.A.C. 6A:26
2. The EPA's Revised Technical Guidance - "3Ts for Reduced Lead in Drinking Water in Schools"
3. Guidance Document from NJDEP Division of Water Supply and Geoscience – "Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water".

Sixty six (66) first draw samples, along with one field blank for quality control purposes, were collected.

All samples were labeled with a unique identification number and transported to the Suburban Laboratory for analysis for lead in drinking water using EPA Method 200.8.

-END OF SECTION-



4.0 DISCUSSION & RECOMMENDATIONS

According to the US EPA, lead enters drinking water primarily through plumbing materials.

For further information on guidance protocols and Action Levels that were followed please refer to:

1. N.J.A.C. 6A:26
2. The EPA's Revised Technical Guidance - "3Ts for Reduced Lead in Drinking Water in Schools"
3. Guidance Document from NJDEP Division of Water Supply and Geoscience – "Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water".

Based on laboratory analysis of the samples analyzed, four (4) sample exceeded the action limit.

Immediate / Short Term Action Required:

1. Immediately discontinue using water at locations exceeding the NJDEP 15.5 ppb Action Level.
2. Follow-up flush samples for the outlets that exceeded the action limit must be collected and submitted to the laboratory for analysis.
3. Refer to EPA's "**for Reducing Lead in Drinking Water in Schools and Child Care Facilities**" for other short term and long term suggested remediation measures and notification procedures.

The type of samples collected for this assessment are referred to as grab samples. Grab samples are individual discrete samples collected at a specific time and location and are reflective of the conditions at that time of collection.

It is important to note that the Lead Hazard Assessment was a snap shot of the conditions existing at the time of the assessment and conditions may vary with time.

-END OF SECTION-



5.0 DISCLAIMER

The Lead Hazard Assessment has limitations with regards to identification of actual health and environmental issues. It is limited to only those items listed in the report and all items reflect conditions at the time of the assessment only.

Westchester Environmental LLC warrants only that the contents of this report constitute an informed discussion of the assessment at the subject property and is prepared exclusively for, and is confidential to, the above noted client. Westchester Environmental LLC assumes no liability with regards to the use of this information or decisions, which are made regarding the subject property. The user(s) of this information must use their own best judgment to determine the appropriate course of action.

Westchester Environmental LLC

A handwritten signature in black ink, appearing to read 'Noel Abraham', followed by a horizontal line.

Noel Abraham
Environmental Specialist

-END OF REPORT-

APPENDIX I

**LEAD IN DRINKING WATER SAMPLING
CHAINS-OF-CUSTODY & LAB REPORTS**



Results Report

Order ID: 1L03287

Westchester Environmental
1248 Wrights Lane
West Chester, PA 19380

Project: Butler SD - HS, Decker & Butler
38 Bartholdi Ave
Butler, NJ 07405

Attn: Noel Abraham

Regulatory ID:

Sample Number: 1L03287-01
Collector: NPA

Site: BHS-LL-SPOE-Boys Rm near 118
Collect Date: 12/11/2021 9:01 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 12/20/21 CMV 12/21/21 8:30 RPV

Sample Number: 1L03287-02
Collector: NPA

Site: BHS-LL-DW-Hall o/s 101
Collect Date: 12/11/2021 9:02 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 2.34 µg/L EPA 200.8 1.00 1 12/20/21 CMV 12/21/21 7:47 RPV

Sample Number: 1L03287-03
Collector: NPA

Site: BHS-LL-DW-Hall o/s Guidance
Collect Date: 12/11/2021 9:03 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 12/20/21 CMV 12/21/21 8:26 RPV

Sample Number: 1L03287-04
Collector: NPA

Site: BHS-LL-WC-Hall o/s 129
Collect Date: 12/11/2021 9:04 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 4.49 µg/L EPA 200.8 1.00 1 12/20/21 CMV 12/21/21 8:24 RPV

Sample Number: 1L03287-05
Collector: NPA

Site: BHS-ML-WC-Hall o/s attendance
Collect Date: 12/11/2021 9:05 am

Sample ID:
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 12/20/21 CMV 12/21/21 8:22 RPV

Report Generated On: 12/28/2021 11:31 am
STL_Results Revision #1.9

1L03287
Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1L03287-06	Site: BHS-ML-BF-Hall o/s attendance	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 9:06 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 8:20	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-07	Site: BHS-ML-WC-Hall o/s 210	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 9:07 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	5.63	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 8:47	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-08	Site: BHS-TL-FS-Faculty Room	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 9:08 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.16	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 8:28	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-09	Site: Art Bldg-LL-SPOE- Boiler Room	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:20 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 8:45	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-10	Site: Art Bldg-ML-NS-Nurse	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:21 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 8:41	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-11	Site: Art Bldg-ML-NS-Nurse Patient Rm	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:22 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	23.4	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 8:39	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-12	Site: Art Bldg-ML-S-Sky lands Rm	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:23 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 8:37	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Report Generated On: 12/28/2021 11:31 am 1L03287
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1L03287-13	Site: Art Bldg-ML-IM-Trainers Rm	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:24 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 9:04	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-14	Site: Art Bldg-ML-S-Trainers Rm	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:25 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 9:02	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-15	Site: Art Bldg-ML-WC-Hall o/s Weight Rm	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:26 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 8:43	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-16	Site: Art Bldg-ML-BF-Hall o/s Weigth Rm	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:27 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 8:53	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-17	Site: Art Bldg-ML-WC-Hall o/s Girls Rm	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:28 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	5.71	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 8:51	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-18	Site: Art Bldg-ML-WC-Cafeteria Left	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:29 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 8:49	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-19	Site: Art Bldg-ML-BF-Cafeteria Left	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:30 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 7:53	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Report Generated On: 12/28/2021 11:31 am 1L03287
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1L03287-20	Site: Art Bldg-ML-WC-Cafeteria Right	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:31 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 8:55	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-21	Site: Art Bldg-ML-WC-Boys Locker Rm	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:32 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 7:57	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-22	Site: Art Bldg-ML-BF-BOYS LOCKER RM	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:33 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 9:14	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-23	Site: Art Bldg-ML-WC-Girls Locker Rm	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:34 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 9:12	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-24	Site: Art Bldg-ML-BF-Girls Locker Rm	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:35 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 9:10	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-25	Site: Art Bldg-ML-FP-Kitchen 2	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:36 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.61	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 9:08	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-26	Site: Art Bldg-ML-FP-Kitchen 3	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:37 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.63	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 9:06	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Report Generated On: 12/28/2021 11:31 am 1L03287
 STL_Results Revision #1.9 Effective: 04/16/2020





Sample Number: 1L03287-28	Site: Art Bldg-LL-WC-Bsmt Locker RM	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:39 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.34	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 9:16	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-29	Site: Art Bldg-TL-WC-Hall o/s Rm 335 Left	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:40 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	9.25	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 9:31	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-30	Site: Art Bldg-TL-WC-Hall o/s Rm 335 Right	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:41 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.42	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 9:29	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-31	Site: Art Bldg-TL-WC-Hall O/s Rm 336	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:42 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 9:27	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-32	Site: Art Bldg-TL-BF-Hall O/s Rm 336	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:43 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 9:20	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-33	Site: Art Bldg-TL-FP-Foods Lab 1	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:44 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.90	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 9:18	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-34	Site: Art Bldg-TL-FP-Foods Lab 2	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:45 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.54	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 9:33	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Report Generated On: 12/28/2021 11:31 am 1L03287
 STL_Results Revision #1.9 Effective: 04/16/2020





Sample Number: 1L03287-35	Site: Art Bldg-TL-FP-Foods Lab 3	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:46 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.68	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 10:07	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-36	Site: Art Bldg-TL-FP-Foods Lab 4	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:47 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.43	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 9:39	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-37	Site: Art Bldg-TL-FP-Foods Lab 5	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:48 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	4.06	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 8:16	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-38	Site: Art Bldg-TL-FP-Foods Lab 6	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:49 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.97	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 9:37	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 1L03287-39	Site: Art Bldg-TL-S-AD Office 334 L	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:50 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	111	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 12:02	RPV
------	-----	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-40	Site: Art Bldg-TL-S-AD office 334 R	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:51 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	122	µg/L	EPA 200.8	1.00	1	12/15/21	RPV	12/22/21 17:36	RPV
------	-----	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-41	Site: Art Bldg-TL-WC-Hall o/s BOE Offices	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:52 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/20/21	CMV	12/21/21 9:41	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Report Generated On: 12/28/2021 11:31 am 1L03287
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1L03287-42	Site: Art Bldg-TL-BF-Hall o/s BOE Office	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:53 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/15/21	MKR	12/21/21 10:31	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-43	Site: Art Bldg-TL-S-BOE Office Rm 13	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 8:54 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/15/21	MKR	12/21/21 10:20	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-44	Site: BAD-1FL-SPOE-Kitchen	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 9:56 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/15/21	MKR	12/21/21 10:35	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-45	Site: BAD-1FL-FP1-Kitchen	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 9:57 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.14	µg/L	EPA 200.8	1.00	1	12/15/21	MKR	12/21/21 10:37	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-46	Site: BAD-1FL-KO-Kitchen	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 9:58 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	4.54	µg/L	EPA 200.8	1.00	1	12/15/21	MKR	12/21/21 10:43	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-47	Site: BAD-1FL-WC-Hall o/s Kitchen	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 9:59 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/15/21	MKR	12/21/21 10:45	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-48	Site: BAD-1FL-BF-Hall o/s Kitchen	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 10:00 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/15/21	MKR	12/21/21 10:47	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 12/28/2021 11:31 am 1L03287
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1L03287-49	Site: BAD-1FL-NS- Nurse	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 10:01 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/15/21	MKR	12/21/21 10:33	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-50	Site: BAD-1FL-FS-Faculty Rm	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 10:02 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.81	µg/L	EPA 200.8	1.00	1	12/15/21	MKR	12/21/21 10:52	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-51	Site: BAD-1FL-WC-Hall o/s Rm 28	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 10:03 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/15/21	MKR	12/21/21 10:54	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-52	Site: BAD-2FL-BF-HALL o/s Rm 28	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 10:04 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/15/21	MKR	12/21/21 10:56	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-53	Site: BAD-2FL-WC-Hall o/s Rm 35	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 10:06 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/15/21	MKR	12/21/21 10:58	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-54	Site: BAD--BF-Hall o/s Rm 35	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 10:07 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/15/21	MKR	12/21/21 11:00	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-55	Site: BAD--FS-Faculty Rm 36	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 10:08 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.22	µg/L	EPA 200.8	1.00	1	12/15/21	MKR	12/21/21 10:49	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 12/28/2021 11:31 am 1L03287
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

Sample Number: 1L03287-56	Site: BRB-1FL-POE-Boiler Room	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 9:30 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/15/21	MKR	12/21/21 11:08	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-57	Site: BRB-1FL-FP-Special Serviss	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 9:31 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	52.4	µg/L	EPA 200.8	1.00	1	12/15/21	MKR	12/21/21 11:10	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-58	Site: BRB-1FL-FP-Kitchen	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 9:32 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	5.77	µg/L	EPA 200.8	1.00	1	12/15/21	MKR	12/21/21 11:12	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-59	Site: BRB-1FL-FS-Faculty 156	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 9:33 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.22	µg/L	EPA 200.8	1.00	1	12/15/21	MKR	12/21/21 11:14	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-60	Site: BRB-1FL-WC-Hall o/s Guidance-L	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 9:34 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/15/21	MKR	12/21/21 10:27	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-61	Site: BRB-1FL-BF-Hall o/s Guidance-R	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 9:35 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/15/21	MKR	12/21/21 11:02	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-62	Site: BRB-1FL-WC-Hall o/s 119 Left	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 9:36 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/15/21	RPV	12/27/21 17:06	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 12/28/2021 11:31 am 1L03287
 STL_Results Revision #1.9 Effective: 04/16/2020





Sample Number: 1L03287-63	Site: BRB-1FL-WC-Hall o/s Nurse-L	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 9:37 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/15/21	RPV	12/27/21 17:14	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-64	Site: BRB-1FL-BF-Hall o/s Nurse-R	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 9:38 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/15/21	RPV	12/27/21 17:15	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-65	Site: BRB-1FL-NS-Nurse	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 9:39 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.97	µg/L	EPA 200.8	1.00	1	12/15/21	RPV	12/27/21 17:17	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-66	Site: BRB-1FL-WC-Hall o/s Gym-L	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 9:40 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/15/21	RPV	12/27/21 17:26	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-67	Site: BRB-1FL-BF-Hall o/s Gym-L	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 9:41 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/15/21	RPV	12/27/21 17:27	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1L03287-68	Site: Field Blank	Sample ID:
Collector: NPA	Collect Date: 12/11/2021 10:15 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	12/15/21	RPV	12/27/21 17:29	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 12/28/2021 11:31 am 1L03287
 STL_Results Revision #1.9 Effective: 04/16/2020





SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.


Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager II

Report Generated On: 12/28/2021 11:31 am 1L03287
STL_Results Revision #1.9 Effective: 04/16/2020





1L03287
Lisa F. Care



Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Retention (Check One) Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	Butler SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	High School, Decker, & Butler
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		38 Bartholdi Ave, Butler, NJ 07405
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	BHS-LL-SPOE-Boys Rm near	12/11/21	09:01 AM	NPA	001	Pb EPA 200.8	1	PW	G	P	H	Boys Rm near 118
First	BHS-LL-DW-Hall o/s 101	12/11/21	09:02 AM	NPA	002	Pb EPA 200.8	1	PW	G	P	H	Hall o/s 101
First	BHS-LL-DW-Hall o/s Guidance	12/11/21	09:03 AM	NPA	003	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Guidance
First	BHS-LL-WC-Hall o/s 129	12/11/21	09:04 AM	NPA	004	Pb EPA 200.8	1	PW	G	P	H	Hall o/s 129
First	BHS-ML-WC-Hall o/s attendan	12/11/21	09:05 AM	NPA	005	Pb EPA 200.8	1	PW	G	P	H	Hall o/s attendance
First	BHS-ML-BF-Hall o/s attendan	12/11/21	09:06 AM	NPA	006	Pb EPA 200.8	1	PW	G	P	H	Hall o/s attendance
First	BHS-ML-WC-Hall o/s 210	12/11/21	09:07 AM	NPA	007	Pb EPA 200.8	1	PW	G	P	H	Hall o/s 210
First	BHS-TL-FS-Faculty Room	12/11/21	09:08 AM	NPA	008	Pb EPA 200.8	1	PW	G	P	H	Faculty Room
Flush	Art Bldg-LL-SPOE- Boiler Roo	12/11/21	08:20 AM	NPA	009	Pb EPA 200.8	1	PW	G	P	H	Boiler Room
First	Art Bldg-ML-NS-Nurse	12/11/21	08:21 AM	NPA	010	Pb EPA 200.8	1	PW	G	P	H	Nurse

Relinquished by:

Date: 12/13/21

Time: 15:00

Received By:

Date: 12/14/21

Temp °C: 15

Time: Acceptable Y / N

Relinquished by:

Date: 12/14/21

Temp °C: 15

Time: Acceptable Y / N

Received in Lab By:

Date: 12-14-21

Temp °C: 15 °C

Time: Acceptable Y / N

1330

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <input checked="" type="radio"/> Y <input type="radio"/> N	NPW = Non-Potable Water	P = Plastic
Number of containers match number on COC? <input checked="" type="radio"/> Y <input type="radio"/> N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass
All containers intact <input checked="" type="radio"/> Y <input type="radio"/> N	PW = Potable Water (not for SWDA compliance)	O = Other
Tests within holding times <input checked="" type="radio"/> Y <input type="radio"/> N	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key
40 ml. VOA vials free of headspace? <input checked="" type="radio"/> Y <input type="radio"/> N	Sample Type Key	H = Sodium Thiosulphate
	G = Grab	Acid
	8 HC = 8 Hour Composite	A = Ascorbic
	24 HC = 24 Hour Composite	H = HNO3
		C = HCl
		S = S
		H2SO4
		OH = NaOH
		O = Other
		None Required
		NA =



1L03287
Lisa F. Care



Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

(Check One) Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	Butler SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	High School, Decker, & Butler
	West Chester, PA 19380	Email:	nabraham@westchesterenvironmental.com		38 Bartholdi Ave, Butler, NJ 07405
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
• First	Art Bldg-ML-NS-Nurse Patient Rm	12/11/21	08:22 AM	NPA	011	Pb EPA 200.8	1	PW	G	P	H	Nurse Patient Rm
• First	Art Bldg-ML-S-Sky lands Rm	12/11/21	08:23 AM	NPA	012	Pb EPA 200.8	1	PW	G	P	H	Sky lands Rm
• First	Art Bldg-ML-IM-Trainers Rm	12/11/21	08:24 AM	NPA	013	Pb EPA 200.8	1	PW	G	P	H	Trainers Rm
• First	Art Bldg-ML-S-Trainers Rm	12/11/21	08:25 AM	NPA	014	Pb EPA 200.8	1	PW	G	P	H	Trainers Rm
• First	Art Bldg-ML-WC-Hall o/s Weight R	12/11/21	08:26 AM	NPA	015	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Weight Rm
• First	Art Bldg-ML-BF-Hall o/s Weigh Rm	12/11/21	08:27 AM	NPA	016	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Weigh Rm
• First	Art Bldg-ML-WC-Hall o/s Girls Rm	12/11/21	08:28 AM	NPA	017	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Girls Rm
• First	Art Bldg-ML-WC-Cafeteria Left	12/11/21	08:29 AM	NPA	018	Pb EPA 200.8	1	PW	G	P	H	Cafeteria Left
• First	Art Bldg-ML-BF-Cafeteria Left	12/11/21	08:30 AM	NPA	019	Pb EPA 200.8	1	PW	G	P	H	Cafeteria Left
• First	Art Bldg-ML-WC-Cafeteria Right	12/11/21	08:31 AM	NPA	020	Pb EPA 200.8	1	PW	G	P	H	Cafeteria Right

Relinquished by: *[Signature]* Date: _____ Time: _____

Received By: *[Signature]* Date: _____ Temp °C: _____
Time: Acceptable Y / N

Relinquished by: *[Signature]* Date: _____ Temp °C: _____
Time: Acceptable Y / N

Received in Lab By: *[Signature]* Date: 12-14-21 Temp °C: 20 °C
Time: 1330 Acceptable Y / N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	NPW = Non-Potable Water	P = Plastic
Number of containers match number on COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass
All containers intact <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	PW = Potable Water (not for SWDA compliance)	O = Other
Tests within holding times <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key
40 ml. VOA vials free of headspace? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Sample Type Key	H = Sodium
	G = Grab	Thiosulphate Acid A = Ascorbic H = HNO3
	8 HC = 8 Hour Composite	C = HCl S =
	24 HC = 24 Hour Composite	H2SO4 OH = NaOH NA =
	D = Distribution	O = Other
	E = Entry Point	None Required
	R = Raw	
	C = Check	
	S = Special	
	M = Maximum Residence	



1L03287
Lisa F. Care



Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.		Project Name:	Butler SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com	
Contact Name:	Noel Abraham	Payment / P.O. Info:	38 Bartholdi Ave, Butler, NJ 07405	

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
• First	Art Bldg-ML-WC-Boys Locker Rm	12/11/21	08:32 AM	NPA	021	Pb EPA 200.8	1	PW	G	P	H	Boys Locker Rm
• First	Art Bldg-ML-BF-BOYS LOCKER R	12/11/21	08:33 AM	NPA	022	Pb EPA 200.8	1	PW	G	P	H	BOYS LOCKER RM
• First	Art Bldg-ML-WC-Girls Locker Rm	12/11/21	08:34 AM	NPA	023	Pb EPA 200.8	1	PW	G	P	H	Girls Locker Rm
• First	Art Bldg-ML-BF-Girls Locker Rm	12/11/21	08:35 AM	NPA	024	Pb EPA 200.8	1	PW	G	P	H	Girls Locker Rm
• First	Art Bldg-ML-FP-Kitchen 2	12/11/21	08:36 AM	NPA	025	Pb EPA 200.8	1	PW	G	P	H	Kitchen 2
• First	Art Bldg-ML-FP-Kitchen 3	12/11/21	08:37 AM	NPA	026	Pb EPA 200.8	1	PW	G	P	H	Kitchen 3
• First	Art Bldg-ML-FP-Kitchen 5	12/11/21	08:38 AM	NPA	027	Pb EPA 200.8	1	PW	G	P	H	Kitchen 5
• First	Art Bldg-LL-WC-Bsmt Locker RM	12/11/21	08:39 AM	NPA	028	Pb EPA 200.8	1	PW	G	P	H	Bsmt Locker RM
• First	Art Bldg-TL-WC-Hall o/s Rm 335 L	12/11/21	08:40 AM	NPA	029	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 335 Left
• First	Art Bldg-TL-WC-Hall o/s Rm 335 R	12/11/21	08:41 AM	NPA	030	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 335 Right

did not receive per 12-14-21

Relinquished by: *[Signature]* Date: _____ Temp °C: _____
 Time: _____ Acceptable Y / N

Received By: *[Signature]* Date: _____ Temp °C: _____
 Time: _____ Acceptable Y / N

Relinquished by: *[Signature]* Date: _____ Temp °C: _____
 Time: _____ Acceptable Y / N

Received in Lab By: *[Signature]* Date: 12-14-21 Temp °C: 20 °C
 Time: 1330 Acceptable Y / N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	NPW = Non-Potable Water	P = Plastic
Number of containers match number on COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass
All containers intact <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	PW = Potable Water (not for SWDA compliance)	O = Other
Tests within holding times <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key
40 ml. VOA vials free of headspace? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Sample Type Key	H = Sodium
	G = Grab	Thiosulphate Acid
	8 HC = 8 Hour	A = Ascorbic
	Composite	H = HNO3
	R = Raw	C = HCl
	C = Check	H2SO4
	S = Special	G = Other
	M = Maximum Residence	None Required



1L03287
Lisa F. Care



Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburban testinglabs.com

Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.	Project Name:	Butler SD
Address:	1248 Wrights Lane	Phone:	610-431-7545
	West Chester, PA 19380	Email:	nabraham@westchesterenvironmental.com
Contact Name:	Noel Abraham	Payment / P.O. Info:	High School, Decker, & Butler 38 Bartholdi Ave, Butler, NJ 07405

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
• First	Art Bldg-TL-WC-Hall O/s Rm 336	12/11/21	08:42 AM	NPA	031	Pb EPA 200.8	1	PW	G	P	H	Hall O/s Rm 336
• First	Art Bldg-TL-BF-Hall O/s Rm 336	12/11/21	08:43 AM	NPA	032	Pb EPA 200.8	1	PW	G	P	H	Hall O/s Rm 336
• First	Art Bldg-TL-FP-Foods Lab 1	12/11/21	08:44 AM	NPA	033	Pb EPA 200.8	1	PW	G	P	H	Foods Lab 1
• First	Art Bldg-TL-FP-Foods Lab 2	12/11/21	08:45 AM	NPA	034	Pb EPA 200.8	1	PW	G	P	H	Foods Lab 2
• First	Art Bldg-TL-FP-Foods Lab 3	12/11/21	08:46 AM	NPA	035	Pb EPA 200.8	1	PW	G	P	H	Foods Lab 3
• First	Art Bldg-TL-FP-Foods Lab 4	12/11/21	08:47 AM	NPA	036	Pb EPA 200.8	1	PW	G	P	H	Foods Lab 4
• First	Art Bldg-TL-FP-Foods Lab 5	12/11/21	08:48 AM	NPA	037	Pb EPA 200.8	1	PW	G	P	H	Foods Lab 5
• First	Art Bldg-TL-FP-Foods Lab 6	12/11/21	08:49 AM	NPA	038	Pb EPA 200.8	1	PW	G	P	H	Foods Lab 6
• First	Art Bldg-TL-S-AD Office 334 L	12/11/21	08:50 AM	NPA	039	Pb EPA 200.8	1	PW	G	P	H	AD Office 334 L
• First	Art Bldg-TL-S-AD office 334 R	12/11/21	08:51 AM	NPA	040	Pb EPA 200.8	1	PW	G	P	H	AD office 334 R


Relinquished by: *[Signature]* Date: _____ Time: _____

Received By: *[Signature]* Date: _____ Temp °C: _____
Time: _____ Acceptable Y / N

Relinquished by: *[Signature]* Date: _____ Temp °C: _____
Time: _____ Acceptable Y / N

Received in Lab By: *[Signature]* Date: **12-14-21** Temp °C: **15°C**
Time: **1330** Acceptable **Y/N**

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	NPW = Non-Potable Water	P = Plastic
Number of containers match number on COC? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass
All containers intact <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	PW = Potable Water (not for SWDA compliance)	O = Other
Tests within holding times <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key
40 ml. VOA vials free of headspace? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	Sample Type Key	H = Sodium Thiosulphate
	G = Grab	A = Ascorbic Acid
	8 HC = 8 Hour Composite	H = HNO ₃
	D = Distribution	S = HCl
	E = Entry Point	H ₂ SO ₄ = NaOH
	R = Raw	O = Other
	C = Check	None Required
	S = Special	
	M = Maximum Residence	



1L03287
Lisa F. Care



Chain of Custody Record

TAT (Check One) Standard 24hr 48hr 72hr Other

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Client Name:	Westchester Environmental LLC.			Project Name:	Butler SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	High School, Decker, & Butler
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		38 Bartholdi Ave, Butler, NJ 07405
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
• First	Art Bldg-TL-WC-Hall o/s BOE Office	12/11/21	08:52 AM	NPA	041	Pb EPA 200.8	1	PW	G	P	H	Hall o/s BOE Offices
• First	Art Bldg-TL-BF-Hall o/s BOE Office	12/11/21	08:53 AM	NPA	042	Pb EPA 200.8	1	PW	G	P	H	Hall o/s BOE Office
• First	Art Bldg-TL-S-BOE Office Rm 13	12/11/21	08:54 AM	NPA	043	Pb EPA 200.8	1	PW	G	P	H	BOE Office Rm 13
• Flush	BAD-1FL-SPOE-Kitchen	12/11/21	09:56 AM	NPA	044	Pb EPA 200.8	1	PW	G	P	H	Kitchen
• First	BAD-1FL-FP1-Kitchen	12/11/21	09:57 AM	NPA	045	Pb EPA 200.8	1	PW	G	P	H	Kitchen
• First	BAD-1FL-KO-Kitchen	12/11/21	09:58 AM	NPA	046	Pb EPA 200.8	1	PW	G	P	H	Kitchen
• First	BAD-1FL-WC-Hall o/s Kitchen	12/11/21	09:59 AM	NPA	047	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Kitchen
• First	BAD-1FL-BF-Hall o/s Kitchen	12/11/21	10:00 AM	NPA	048	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Kitchen
• First	BAD-1FL-NS- Nurse	12/11/21	10:01 AM	NPA	049	Pb EPA 200.8	1	PW	G	P	H	Nurse
• First	BAD-1FL-FS-Faculty Rm	12/11/21	10:02 AM	NPA	050	Pb EPA 200.8	1	PW	G	P	H	Faculty Rm


Relinquished by: Date: _____ Time: _____

Received By: Date: _____ Temp °C: _____ Time: _____ Acceptable Y / N

Relinquished by: Date: _____ Temp °C: _____ Time: _____ Acceptable Y / N

Received in Lab By: Date: **12-14-21** Temp °C: **15-C** Time: **1330** Acceptable Y / N

Sample Conditions	Matrix Key	Bottle Type Key	Reporting options
Submitted w/ COC <input checked="" type="checkbox"/> Y / N	NPW = Non-Potable Water	P = Plastic	<input type="checkbox"/> SWDA Reporting
Number of containers match number on COC? <input checked="" type="checkbox"/> Y / N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass	<input type="checkbox"/> PW SID
All containers intact <input checked="" type="checkbox"/> Y / N	PW = Potable Water (not for SWDA compliance)	O = Other	<input type="checkbox"/> Fax
Tests within holding times <input checked="" type="checkbox"/> Y / N	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key	<input type="checkbox"/> Email
40 ml. VOA vials free of headspace? <input checked="" type="checkbox"/> Y / N	Sample Type Key	H = Sodium Thiosulphate	<input type="checkbox"/> Other
	G = Grab	Acid	A = Ascorbic
	8 HC = 8 Hour Composite	C = HCl	H = HNO3
	24 HC = 24 Hour Composite	H2SO4	S =
		O = Other	OH = NaOH
			NA =
	D = Distribution		None Required
	E = Entry Point		Return a copy of this form with Report
	R = Raw		
	C = Check		
	S = Special		
	M = Maximum		
	R = Residence		



1L03287
Lisa F. Care



Chain of Custody Record

TAT (Check One) Standard 24hr 48hr 72hr Other

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Client Name:	Westchester Environmental LLC.			Project Name:	Butler SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	High School, Decker, & Butler
	West Chester, PA 19380				38 Bartholdi Ave, Butler, NJ 07405
Contact Name:	Noel Abraham	Email:	nabraham@westchesterenviromental.com	Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
• First	BAD-1FL-WC-Hall o/s Rm 28	12/11/21	10:03 AM	NPA	051	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 28
• First	BAD-2FL-BF-HALL o/s Rm 28	12/11/21	10:04 AM	NPA	052	Pb EPA 200.8	1	PW	G	P	H	HALL o/s Rm 28
• First	BAD-2FL-DW-Rm 29	12/11/21	10:05 AM	NPA	053	Pb EPA 200.8	1	PW	G	P	H	Rm 29
• First	BAD-2FL-WC-Hall o/s Rm 35	12/11/21	10:06 AM	NPA	054	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 35
• First	BAD-BF-Hall o/s Rm 35	12/11/21	10:07 AM	NPA	055	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Rm 35
• First	BAD-FS-Faculty Rm 36	12/11/21	10:08 AM	NPA	056	Pb EPA 200.8	1	PW	G	P	H	Faculty Rm 36
• Flush	BRB-1FL-POE-Boiler Room	12/11/21	09:30 AM	NPA	057	Pb EPA 200.8	1	PW	G	P	H	Boiler Room
• First	BRB-1FL-FP-Special Servicess	12/11/21	09:31 AM	NPA	058	Pb EPA 200.8	1	PW	G	P	H	Special Servicess
• First	BRB-1FL-FP-Kitchen	12/11/21	09:32 AM	NPA	059	Pb EPA 200.8	1	PW	G	P	H	Kitchen
• First	BRB-1FL-FS-Faculty 156	12/11/21	09:33 AM	NPA	060	Pb EPA 200.8	1	PW	G	P	H	Faculty 156

did not receive sample at 12:14:21

Relinquished by: Date: _____ Time: _____


Received By: Date: _____ Temp °C: _____

Relinquished by: Date: _____ Temp °C: _____

Received in Lab By: Date: 12-14-21 Temp °C: 15°C

Time: 1330

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	NPW = Non-Potable Water	P = Plastic
Number of containers match number on COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass
All containers intact <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	PW = Potable Water (not for SWDA compliance)	O = Other
Tests within holding times <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key
40 ml. VOA vials free of headspace? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Sample Type Key	H = Sodium Thiosulphate
	G = Grab	A = Ascorbic Acid
	8 HC = 8 Hour Composite	H = HNO3
	24 HC = 24 Hour Composite	C = HCl
		S = S
		H2SO4
		OH = NaOH
		O = Other
		None Required
		NA =



1L03287
Lisa F. Care



Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Jard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	Butler SD
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	High School, Decker, & Butler
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		38 Bartholdi Ave, Butler, NJ 07405
Contact Name:	Noel Abraham	Payment / P.O. Info:			

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
• First	BRB-1FL-WC-Hall o/s Guidance-L	12/11/21	09:34 AM	NPA	61	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Guidance-L
• First	BRB-1FL-BF-Hall o/s Guidance-R	12/11/21	09:35 AM	NPA	62	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Guidance-R
• First	BRB-1FL-WC-Hall o/s 119 Left	12/11/21	09:36 AM	NPA	63	Pb EPA 200.8	1	PW	G	P	H	Hall o/s 119 Left
• First	BRB-1FL-WC-Hall o/s Nurse-L	12/11/21	09:37 AM	NPA	64	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Nurse-L
• First	BRB-1FL-BF-Hall o/s Nurse-R	12/11/21	09:38 AM	NPA	65	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Nurse-R
• First	BRB-1FL-NS-Nurse	12/11/21	09:39 AM	NPA	66	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Nurse
• First	BRB-1FL-WC-Hall o/s Gym-L	12/11/21	09:40 AM	NPA	67	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Gym-L
• First	BRB-1FL-BF-Hall o/s Gym-L	12/11/21	09:41 AM	NPA	68	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Gym-L
• First	Field Blank	12/11/21	10:15 AM	NPA	69	Pb EPA 200.8	1	PW	G	P	H	Field Blank

Relinquished by:

Received By:

Relinquished by:

Received in Lab By:

Date:

Time:

Date:

Time:

Date:

Time:

Date:

Time:

Temp °C:

Acceptable Y / N

Temp °C:

Acceptable Y / N

Temp °C: 15 °C

Acceptable Y / N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ CQC <input checked="" type="checkbox"/> N	NPW = Non-Potable Water	P = Plastic
Number of containers match number on CQC? <input checked="" type="checkbox"/> Y / N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass
All containers intact <input checked="" type="checkbox"/> Y / N	PW = Potable Water (not for SWDA compliance)	O = Other
Tests within holding times <input checked="" type="checkbox"/> Y / N	SWDA = Safe Drinking Water Act Potable Sample	Preservative Key
40 ml VOA vials free of headspace? <input checked="" type="checkbox"/> Y / N	Sample Type Key	H = Sodium Thiosulphate
	G = Grab	A = Ascorbic Acid
	8 HC = 8 Hour Composite	H = HNO3
	R = Raw	C = HCl
	C = Check	S =
	S = Special	H2SO4
	M = Maximum Residence	OH = NaOH
		O = Other
		None Required